

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 010234	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/20/2011
NAME OF PROVIDER OR SUPPLIER BROOKDALE PLACE AT WILLOW LAKE LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 2725 LAKE CIRCLE DRIVE INDIANAPOLIS, IN 46268		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
R 000	<p>INITIAL COMMENTS</p> <p>An Environmental Preoccupancy Survey for State Licensure of a Residential Facility for the conversion of a resident room to a therapy room was conducted by the Indiana State Department of Health.</p> <p>Survey Date: 06/20/11</p> <p>Facility Number: 010234 Provider Number: 010234 AIM Number: NA</p> <p>Surveyor: Mark Caraher, Life Safety Code Specialist</p> <p>At this Environmental Preoccupancy Survey, Brookdale Place at Willow Lake LLC was found in compliance with 410 IAC 16.2-5-1.5, Sanitation and Safety Standards and 16.2-5-1.6, Physical Plant Standards of the Indiana Health Facilities Rules for Residential care facilities.</p> <p>This three story facility with a basement was determined to be of Type II (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection on all levels in the corridors, all areas open to the corridors and in the basement. The facility has a capacity of 86 and had a census of 46 at the time of this survey.</p> <p>Quality Review by Robert Booher, REHS, Life Safety Code Specialist-Medical Surveyor on 06/21/11.</p>	R 000			

Indiana State Department of Health

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

STATE FORM

6899

3C8Z11

If continuation sheet 1 of 1